Certificate Number Baseefa03ATEX0749U

1



Issued 22 January 2004 Page 1 of 3

EC - TYPE EXAMINATION CERTIFICATE

2 Component Intended for use on/in an Equipment or Protective System
Intended for use in Potentially Explosive Atmospheres - Directive 94/9/EC

Baseefa03ATEX0749U 3 EC - Type Examination **UNCONTROLLED DOCUMENT** Certificate Number: THIS DOCUMENT IS NOT Component: A Type TX6911 Enclosure T TO AMENDMENTS 5 Manufacturer: T.E.L Engineering Limited trading as Trolex T.E.L. ENGINEERING LIMITED Stockport, Cheshire, SK7 5DA 6 Address:

- 7 This component and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.
- 8 Baseefa (2001) Ltd. Notified body number 1180, in accordance with Article 9 of the Council Directive 94/9/EC of 23 March 1994, certifies that this component has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of components intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in confidential Report No. 03(C)0994/2

- 9 Compliance with the Essential Health and Safety Requirements has been assured by compliance with:
 - EN 50014: 1997 + Amendments 1 & 2 EN 50018:2000 + Amendment 1 EN50281-1-1: 1998 except in respect of those requirements listed at item 18 of the Schedule.
- 10 The sign "U" is placed after the certificate number. It indicates that this certificate must not be mistaken for a certificate intended for an equipment or protective system. This partial certification may be used as a basis for certification of an equipment or protective system.
- 11 This EC TYPE EXAMINATION CERTIFICATE relates only to the design and construction of the specified Component. Further requirements of the Directive apply to the manufacturing process and supply of this component. These are not covered by this certificate.
- 12 The marking of the component shall include the following :
 - (Ex) II 2 G D EEx d IIB IP66

This certificate may only be reproduced in its entirety, without any change, schedule included.

Baseefa (2001) Ltd. Customer Reference No. 1428

Project File No. 03/0994

This certificate is granted subject to the general terms and conditions of Baseefa (2001) Ltd. It does not necessarily indicate that the equipment may be used in particular industries or circumstances.

Baseefa (2001) Ltd.

Health and Safety Laboratory Site, Harpur Hill,
Buxton, Derbyshire SK17 9JN
Telephone +44 (0) 1298 28255 Fax +44 (0) 1298 28216
e-mail info@baseefa2001.biz web site www.baseefa2001.biz
Registered in England No. 4305578 at 13 Dovedale Crescent, Buxton,
Derbyshire, SK17 9BJ

R S SINCLAIR
DIRECTOR
On behalf of
Baseefa (2001) Ltd.

Certificate Number Baseefa03ATEX0749U



Issued 22 January 2004 Page 2 of 3

13 Schedule

Certificate Number Baseefa03ATEX0749U

15 Description of Component

14

A TX6911 Enclosure comprises a circular fabricated steel plate housing and domed cover. The housing has four thicker pad attached for cable entries or for the attachment of plugs and/or sockets as indicated below.

Type	Certificate	Code	
TX3700.P	BAS02ATEX2278U	— Ex II 2 G EEx d IIB.	
TX3700.S	BASUZATEAZZ/8U		
TX3701.P	DASO2ATEV229111		
TX3701.S	BAS02ATEX2281U		

The cover is attached with 12 off M10 x 16mm long socket head cap screws of grade A2-70 stainless steel, and the interior is provided with a chassis plate for mounting equipment.

16 Report Number

Baseefa Certification Report 03(C)0994/2

17 Schedule of Limitations

UNCONTROLLED DOCUMENT
THIS DOCUMENT IS NOT
SUBJECT TO AMENDMENTS

T.E.L. ENGINEERING LIMITED

This document covers only the empty enclosure. It does not cover the enclosure when used with internally fitted electrical components. When such components are fitted the arrangement must comply with the following limitations and be separately certified by the Certifying Authority.

- Where necessary for safety, the contents of the enclosure shall comply with the appropriate requirements of relevant standards for electrical equipment.
- 2. Rotating or other devices which create turbulence shall not be incorporated.
- Liquids shall not be used when there is risk of producing an explosive mixture by the decomposition of or release of oxygen by these liquids.
- 4 Primary and secondary cells and batteries shall only be used in accordance with Annex E of EN 50018.
- 5 Enclosures which can be opened more quickly than the time necessary for the discharge of incorporated capacitors, or the cooling of hot components shall be labelled AFTER DE-ENERGIZING, DELAY X MINUTES BEFORE OPENING or DO NOT OPEN WHEN AN EXPLOSIVE GAS ATMOSPHERE IS PRESENT.
- 6 Oil-filled circuit breakers and contactors shall not be used.
- All entry or closure devices when fitted shall satisfy the requirements of flameproof joints or be specifically certified with the equipment and be suitable for the conditions of use
- 8 The content of the enclosed apparatus may be placed in any arrangement provided that an area of at least 20% of each cross-sectional area remains free to permit unimpeded gas flow and, therefore, unrestricted development of an explosion.
 - For the purposes of the above separate relief areas may be aggregated provided that each area has a minimum dimension in any direction of 12.5 mm.

Certificate Number Baseefa03ATEX0749U



Issued 22 January 2004 Page 3 of 3

- No holes, whether for mechanical or electrical purpose and whether blind or clear, shall be drilled in the enclosure other than those shown on the Component Certificate drawings.
 Any hole specified in the Component Certificate may be provided but only by the holder of the Component Certificate
- 10 Any subsequent apparatus shall be marked indicating that cover screws of minimum grade A2-70 stainless steel shall be used, or any subsequent equipment certificate shall be marked with an "X", and shall specify that cover screws of minimum grade A2-70 stainless steel shall be used.
- 11 The plugs and sockets are limited to 20A per pin and a total current of 100A.
- 12 When Type TX3700 or TX3701 plugs and sockets are fitted, the devices must be used in conjunction with the appropriate mating cable or stopping devices as defined within the certificates.
- 13 If used in an explosive dust atmosphere the equipment certificate shall specify the need for the cable entries to maintain the ingress protection (IP66) of the enclosure.

18 Essential Health and Safety Requirements

All relevant Essential Health and Safety Requirements are covered by the standards listed at item 9.

19 Drawings and Documents

Number	Sheet	Issue	Date	Description
1/6900/103	1	E	25.11.03	General Assembly - TX6911 Enclosure
1/6900/103	2	E	25.11.03	Entry Details

UNCONTROLLED DOCUMENT
THIS DOCUMENT IS NOT
SUBJECT TO AMENDMENTS

T.E.L. ENGINEERING LIMITED